

Ottawa County Department Of Building Inspection

2013 RESIDENTIAL CODE OHIO ENERGY COMPLIANCE PATH OPTIONS FOR CLIMATE ZONE 5

Compliance shall be demonstrated by meeting the requirements of one of the following options

DESCRIPTION	OPTION 1 2009 IECC	OPTION 2 RCO 1101-1104	OPTION 3 RCO 1105 (OHBA)	
			OPTION 3A OHBA Path 1	OPTION 3B OHBA Path 2
Minimum Fenestration U-Factor (all glazed fenestration except skylights)	0.35	0.35	0.32	0.32
Skylight Fenestration	0.60	0.60	0.60	0.60
Ceiling R Value	38	38	49	49
Wood Framed Walls R Value	20 or 13 + 5*	20 or 13 + 5*	15 or 13 + 3*	13
Mass Wall R Value (i.e. above grade walls of concrete block, ICF, solid timber logs, etc...)	13/17	13/17	13/17	13/17
Framed Floor R Value	30 **	30 **	30 **	30 **
Basement Wall R Value	10/13 *** (full)	10/13 *** (full)	10/13 *** (min. 4 ft)	10/13 *** (min. 4 ft)
<input checked="" type="checkbox"/> Slab R Value	10 @ 2 ft.	10 @ 2 ft.	10 @ 2 ft.	10 @ 2 ft.
Crawl Space wall R Value	10/13 ***	10/13 ***	10/13 ***	10/13 ***
Blower Door Test	Yes @	Yes @	Yes †	Yes †
Ducts must be tested for tightness (IECC 403.2.2).	Yes ‡	Yes ‡	Yes ‡ †	Yes ‡ †
<input checked="" type="checkbox"/> Supply ducts in attic shall be sealed and insulated to a minimum of	R-8	R-8	R-8	R-8
<input checked="" type="checkbox"/> All other ducts (outside the building envelope) shall be sealed and insulated to a minimum of	R-6	R-6	R-6	R-6
Air Sealing (IECC 402.4) of Plates, Walls, Windows, Doors, Utility Penetrations, Attic Access, Recessed	Yes	Yes	Yes	Yes
<input checked="" type="checkbox"/> Wood-burning fireplaces shall have gasketed doors and outdoor combustion air	Yes	Yes	Yes	Yes
Access doors from conditioned spaces to unconditioned space shall be weather-stripped	Yes	Yes	Yes	Yes
Circulating hot water systems piping shall be insulated to at least R- per Section 1103.4	R-2 (all)	R-2 (all)	R-2 first 5 ft	R-2 first 5 ft
Mechanical system piping (fluids above 105 F or below 55 F) must be insulated to a minimum of	R-3	R-3	R-3	R-3
Minimum percentage of high efficacy lighting fixtures	50%	50%	75%	75%
Programmable thermostat required	Yes	Yes	Yes	Yes
Permanent certificate shall be posted on the electrical panel	Yes	Yes	Yes	Yes
Furnace Efficiency Rating	Equipment Sizing shall meet Section M1401.0 of the IRC			
Air Conditioner SEER Rating				

NOTE:

Circle option chosen

or

Submit REScheck

**FORM MUST BE
COMPLETED AND ON
JOB SITE FOR
INSULATION INSPEC
TION.**

NOTES:

- * "13+5" means R-13 cavity insulation plus R-5 insulated sheathing (likewise for "13+3")
 - ** Or insulation sufficient to fill the framing cavity
 - *** 10/13 means R-10 continuous insulation (on the interior or exterior) or R-13 cavity insulation at the interior of the basement/crawl wall
 - For heated slabs R-5 shall be added to the required slab edge R-values
 - @ Exception: Compliance may be determined by a visual inspection based on the criteria listed in IECC Table 402.4.2 (in lieu of blower door)
 - ‡ Exception: Duct tightness test is not required if the air handler and all ducts are located within conditioned space
 - † This requirement will take effect one year after the effective date of this rule (1/1/14)
 - Building framing cavities shall not be used as supply ducts
 - Exception: Pre-Manufactured fireplaces must be installed per manufacturer's instructions (which may or may not include gasketed doors and outside air)
- (OHBA) Ohio Home Builders Association
(RCO) Residential Code of Ohio
(IECC) International Energy Conservation Code

Builder: _____ Project Address: _____ City: _____