



Mechanical | Electrical | Plumbing | Technology | Safety

Ottawa County Courthouse
Cooling Tower Replacement
315 Madison Street
Port Clinton Ohio 43452

ADDENDUM NO. 1

August 24, 2022

The following additions, alterations, deletions and/or clarifications shall be part of the Base Bid as much as if they were originally included in the Contract Documents.

I. SPECIFICATIONS:

A. No change

II. DRAWINGS:

A. Drawing M-2 – Partial Floor Plan - HVAC (Drawing Not Reissued):

1. Expansion tank shall have a minimum volume of 90 gallons and minimum acceptance of 34 gallons.

END OF ADDENDUM NO. 1