

Ottawa County Engineer's Office
David A. Brunkhorst, P.E., R.S.
Ottawa County Engineer

315 Madison Street
Room 106
Port Clinton, Ohio 43452

Toll Free: (800) 788-8803
Phone: (419) 734-6777
Fax: (419) 734-6768

From: Ottawa County Engineer's Office
To: All Plan Holders
Date: July 23, 2014
RE: Held Ditch (Branch #1) Reconstruction

General Questions and Responses:

1. Question – Clarify Item #10. On the proposal this item is called out as “8-inch Conduit, Type E, 707.33, As Per Plan”, which is double wall plastic pipe. In the plans (General Summary, General Notes and Plan & Profile Sheets) this item is called out as single wall plastic or Type 707.32. Which type of pipe is to be used?
 - 707.32 is to be used. This line item contains a typo in the proposal sheet and should be called out as “8-inch Conduit, Type E, 707.32, As Per Plan”.

No changes have been made to the original proposal documents

If you have any questions please call the Ottawa County Engineer's Office at 419 734-6777.

Sincerely,



David A Brunkhorst, PE, RS
Ottawa County Engineer