



**MARK
LECKY
ARCHITECTS,
LLC**
Architects/Planners

668 S. Ninth St.
Columbus Ohio
43206
Tel
614-621-9339(0)
E Mail
Lecky@MLArchs.com

CLARIFICATION 01

07/14/2015

CLARIFICATION 01 TO THE DRAWINGS AND SPECIFICATIONS FOR:

Exterior Repairs / Maintenance Ottawa County Courthouse Complex

315 Madison Street
Port Clinton, Ohio 43452

TO ALL BIDDERS:

This Clarification revises and/or supplements the original Plans and Specifications and any previously issued addenda and shall be considered in preparing proposals and shall become a part of the Contract Documents. This Clarification must be noted as received and considered on all bid submittals.

This Clarification is being emailed to all contractors, subcontractors, suppliers, engineers, plan rooms, and project representatives who have received official bid document sets from Mark Lecky Architects, LLC on this project. No copies will be faxed or mailed unless specifically requested.

All Contractors are cautioned to review all drawings and spec sections and not just their specific trade sections, since their specific trade work may be shown on any drawing or spec section.

ITEM 1 MISCELLANEOUS:

1.01 Window Work Clarifications:

1. Clarify text at: Section 08510, 1.01, C, 1, a & Sheet C1A, Window Work Schedule Notes, 1, A to read that this note is referring to replacement of sealant joints located at window perimeter, panning and framing locations. (All sealant and glazing seals are to be replaced, see details). Note: panning is not being replaced typically.
2. Clarify text at: Section 08510, 1.01, D, 1, d & Sheet C1A, Alternate Bid Work, 1, D to read "1" insulating bronze tinted glass as specified (in section 08800), in lieu of "spandrel". Existing vision glass is being replaced with tinted vision glass.
3. Sheet C1B: Detail @ Ached Spandrel Heads: Clarify that the window is exterior glazed and that no interior access is required. (Noted as "Exterior Stops")

End of Clarification 1

Pages Included: CLR01- Pg 1.

Mark D Lecky
Principal Architect