

Ottawa County Engineer's Office

Ronald P. Lajti Jr., P.E., P.S.

Ottawa County Engineer

315 Madison Street
Room 106
Port Clinton, Ohio 43452

Phone: (419) 734-6777

Toll Free: (800) 788-8803

Fax: (419) 734-6768

From: Ottawa County Engineer's Office
To: All Plan Holders
Date: January 28, 2016
RE: Billman Road Turnpike Mitigation Project - Addendum No. 2

General:

1. **Question** – Line Item 9 Erosion Control. Should the proposal show the bid price at \$1.00 and the total \$500? Generally ODOT proposals the unit price/total already included.

Response: Line Item 9 is set up as a unit bid item with a quantity of 500 each. The contractor shall bid the unit price necessary to calculate a total bid amount to cover the work they anticipate to be required to conform to the requirements of SS832 for the project based on their means and methods.

2. **Question** – Line Item 3 Pavement Repair, APP. What depth should the repair be and what type of asphalt replacement?

Response: The quantity for pavement repairs was calculated using a 6" depth. Actual depth of repairs will ultimately be determined onsite by the engineer. Asphalt material conforming to Item 301 – Asphalt Concrete Base, PG64-22 shall be used for pavement repairs.

Place a copy of this notice of Addendum in your bid package as outlined in the last paragraph of the QUESTIONS, INTERPRETATION and ADDENDA section of the bid package.

If you have any questions regarding this addendum please call the Ottawa County Engineer's Office at 419 734-6777.

Sincerely,



Ronald P. Lajti, Jr., PE, PS
Ottawa County Engineer

RPL/jpm

File