

Ottawa County Engineer's Office

Ronald P. Lajti, Jr., P.E., P.S.
Ottawa County Engineer

8247 W. State Route 163
Oak Harbor, Ohio 43449

Phone: 419-734-6777
Fax: 419-734-6768

From: Ottawa County Engineer's Office
Date: May 1, 2017
Subject: 2017 Asphalt Concrete Thinlay of Genoa-Clay Center Road CR#51

General questions and responses:

1. Question – There are existing rumble strips in the NB lane leading up to SR 579. Will the county require any treatment of these before paving or will the contractor just pave over them?

Response – No, there will not be any necessary treatment before paving. The contractor is to pave over them.

2. Question – There are a few monument boxes/manholes that will be encountered during paving. Will these be required to be adjusted or just feathered into?

Response – No, these will not require adjusting. These items will either be feathered into or risers will be supplied at the time of construction.

No changes have been made to the original proposal documents. This information is provided for clarification purposes only.

Respectfully,



Ronald P. Lajti, Jr., P.E., P.S.
Ottawa County Engineer

RPL/tm