

Ottawa County Engineer's Office

Ronald P. Lajti, Jr., P.E., P.S.
Ottawa County Engineer

8247 W. State Route 163
Oak Harbor, Ohio 43449

Phone: 419-734-6777
Fax: 419-734-6768

From: Ottawa County Engineer's Office
Date: July 26, 2017
Subject: Ottawa-Lucas Road (TR-3) Reconstruction – Q&A No. 1

General questions and responses:

1. Question: Can you provide the existing pavement depth?

Response: The County has no records regarding pavement buildup for this road. However, based upon limited test holes dug at the site, the pavement buildup was found to have an average of 3" of heavily weathered bituminous pavement with 6" to 8" of compacted stone base. This information shall be considered approximate and may not be fully representative of the pavement thicknesses for the full length of the project.

No changes have been made to the original proposal documents. This information is provided for clarification purposes only.

Sincerely,



Ronald P. Lajti, Jr., PE, PS
Ottawa County Engineer

RPL/jpm