

# Ottawa County Engineer's Office

Ronald P. Lajti, Jr., P.E., P.S.  
Ottawa County Engineer

8247 W. State Route 163  
Oak Harbor, Ohio 43449

Phone: 419-734-6777  
Fax: 419-734-6768

FROM: Ottawa County Engineer's Office  
DATE: June 7, 2018  
SUBJECT: Leiser Ditch Bottom Excavation and Restoration Project -  
**Question and Answer #2**


General Question(s) and response(s):

1. **Question:** Bid Item #17 has a bid quantity of 100 LF. Page 2 of the plans show installation of 80' of pipe. Where is the remaining 20' to be installed?

**Answer:** The remaining 20' of pipe is to be installed at approximately Sta. 59+56 to 59+26. This pipe will be connected to the 48" HDPE installed by O.D.O.T. with the new basin near State Route # 19.

Questions regarding this information may be directed to the Soil and Water Conservation District at (419) 898-1595.

Sincerely,



Ronald P. Lajti, Jr., P.E., P.S.  
Ottawa County Engineer

RPL/tm

# Ottawa County Engineer's Office

Ronald P. Lajti, Jr., P.E., P.S.  
Ottawa County Engineer

8247 West State Route #163  
Oak Harbor, Ohio 43449

Phone: (419) 734-6777  
Fax: (419) 734-6768

## Bid Project Inquiries

Project Name: Leiser Ditch Bottom Excavation & Restoration Project

Inquirer's Name: Fred T. Sander, P.E.

Company Name: Geo. Gradel Co.

Phone: 419-691-7123 Fax: 419-691-0877

E-Mail Address: ftsander@geogradelco.com

Inquiry: \_\_\_\_\_

Bid Item 17: 48" Conduit Type C, 707.33

Bid Quantity is 100'

On Plan Sheet 2, The ditch profile showa two (2) sections  
of 40' of 48" HDPE (80'). Is there another location for the  
remaining 20' of 48" HDPE?

THE REMAINING 20' OF 48" HDPE WILL BE INSTALLED  
ⓐ APPROX. STA. 59+56 TO 59+76 AND BE CONNECTED  
TO THE 48" HDPE INSTALLED BY ODOT WITH THE NEW  
BASINS ⓐ SR-19.